BRIGHTWELL

Declaration of **DVGW** Certification

Chemical dilution equipment — EcoMix and EcoMulti

Doc. Reference No.: BW-DECL-2611-001 Rev 1.0

Equipment covered

EcoMix	DPHB-WK ECOMIX HIGH FLOW, BRIGHTGAP DPLBB-WK ECOMIX LOW FLOW, BRIGHTGAP	DW-0625DQ0722
EcoMulti	DX4H-WK ECOMULTI HIGH FLOW, BRIGHTGAP DX4L-WK ECOMULTI LOW FLOW, BRIGHTGAP	DW-0625DQ0723

This statement identifies the Brightwell EcoMix and EcoMulti chemical dilution equipment and specifies a recommended optimum inlet water temperature of 4 °C to 23 °C. The hygienic safety of all materials that come into contact with drinking water has been proven, and the equipment was evaluated according to the following test basis:

- DVGW Cert ZP 50799
- DVGW W 540-VP
- DIN EN 14452

The company reserves the right to do updates to this certificate when applicable.

On behalf of Brightwell Dosing Ltd.

Signature: 

Name: Delia Da Costa

Position: Project Quality Engineer

Date: 03/Nov/2026